

ADDENDUM NO. FEN 3

Prepared by : Gary Buczkowski Hoffman Estates Park District

Date Issued: February 19, 2015

Project: **Fence installation project at various locations**

NOTE: The following changes are hereby made to the contract documents and insofar as the original contract Documents are inconsistent therewith, the changes herein shall govern. All Bidders shall acknowledge this addendum by inserting its number and date on their bid form.

Items included in this addendum:

Item FEN -3-1

Under Item 1A Maple Park Playground Fencing the Ornamental Aluminum fence post shall be 2 -1/2" not 2" square. This is necessary to accommodate the industrial grade fence rails that need to be inserted into these posts.

Item FEN-3-2

Under Item 4A High Point Park Restroom Wooden Fence screen wall, the shadow boards should be 1" X 6" X 7ft not 2" x 8" x 7ft

END ADDENDUM FEN-3