

## **ADDENDUM NO. FEN 2**

*Prepared by :* Gary Buczkowski Hoffman Estates Park District

*Date Issued:* February 17, 2015

*Project:* **Fence installation project at various locations**

NOTE: The following changes are hereby made to the contract documents and insofar as the original contract Documents are inconsistent therewith, the changes herein shall govern. All Bidders shall acknowledge this addendum by inserting its number and date on their bid form.

*Items included in this addendum:*

Item FEN -2-1 The gate posts on the service gates shall 3" square cored into the 12" wide concrete curb at Maple and 3" round set into 42" deep concrete footings at evergreen Park.

Item FEN-2-2 The fence fabric shall be manufactured from galvanized steel wire. The weight of zinc shall meet the requirements of ASTM F668, Table 4. Galvanized wire shall be PVC-coated to meet the requirements of ASTM F668. The class of the fence fabric shall be 2" x 2" **BLACK VINYL CHAIN LINK FABRIC 6 GAUGE STEEL CORE FUSE AND BONDED 5 GAUGE FINISH.**

Item FEN-2-3 The gate frames on all chain link fence areas shall be made with 1 - 1/5" dia. Galvanized steel pipe coated with black vinyl.

***END ADDENDUM FEN-2***