

## **ADDENDUM NO. FEN 4**

*Prepared by :* Gary Buczkowski Hoffman Estates Park District

*Date Issued:* February 20, 2015

*Project:* **Fence installation project at various locations**

NOTE: The following changes are hereby made to the contract documents and insofar as the original contract Documents are inconsistent therewith, the changes herein shall govern. All Bidders shall acknowledge this addendum by inserting its number and date on their bid form.

*Items included in this addendum:*

Item FEN -4-1

To address conflicting information between the drawings and specifications the following description shall apply:

The ornamental Aluminum fence to be installed at Maple shall be industrial grade with 1" X 1" square pickets no further apart than 3". The top and bottom rails shall be 1 5/8" X 1 5/8" Aluminum. The posts shall be 2 1/2" X 2 1/2" square. Color Black

***END ADDENDUM FEN-4***